



# FIRE ALARM AFFIDAVIT

DATE \_\_\_\_\_ PERMIT NO \_\_\_\_\_

JOB NAME \_\_\_\_\_ SQUARE FEET \_\_\_\_\_

ADDRESS \_\_\_\_\_

CONTRACTOR \_\_\_\_\_ ROC \_\_\_\_\_

EMAIL \_\_\_\_\_ PHONE \_\_\_\_\_

### MUST MEET THESE REQUIREMENTS

- Maximum number of devices allowed to be added, subtracted or relocated is five.
- All work complies with the 2012 IFC, NFPA 72 and CAFMA Fire Protection Standards.
- All notification appliances are located in accordance with the current adopted NFPA 72. Notification Appliance Circuit (NAC), End of Line (EOL) Voltage drop calculations meet manufacturer's specifications (When end of line notification circuit voltage is not calculated, alarm voltage measurement may be used.)
- Smoke/Heat detector spacing complies with the current adopted NFPA 72.
- Voltage drop is adequate to all appliances per manufacturer's specifications.
- Battery supplies are capable of supporting the system modifications and meet manufacturer's specifications.
- Compatibility of appliances and devices are in accordance with the FACP manufacturer's specifications.
- Final approval shall be subject to on-site test and inspection.

In addition, I understand the following documentation shall be provided to the authority having jurisdiction:

- A sketch attached to this document showing the area of work within the building.
- Scope of work.

SUBMITTING INDIVIDUAL \_\_\_\_\_  
(Please print)

SUBMITTING INDIVIDUAL \_\_\_\_\_  
(Signature)

ISSUED BY \_\_\_\_\_

PLANS PICKED UP \_\_\_\_\_  
(Please print)

DATE \_\_\_\_\_



All construction permits are valid for 180 days from time of application approval. One 90 day extension may be granted by the fire code official following a written request which demonstrates justifiable cause.